



- ① CLEVIS TYPE PIPE HANGER. PROVIDE COPPER HANGER FOR BARE COPPER PIPE
- ② THREADED ROD CUT TO LENGTH. PROVIDE ADJUSTING NUT BELOW AND LOCKING NUT ABOVE HANGER
- ③ PIPE INSULATION SHIELD CENTERED ON HANGER. ATTACH TO INSULATION WITH ADHESIVE. SHIELD LENGTH SHALL BE PER INSULATION MANUFACTURER
- ④ INSULATION PER SPECIFICATION 15260.
- ⑤ PIPE

NOTE: REFER TO SPECIFICATION 20 05 29 FOR ADDITIONAL REQUIREMENTS.

MD ANDERSON CANCER CENTER
Facilities Planning Design & Construction

ISSUE	DATE
①	05-20-2004

CLEVIS PIPE HANGER

Facility Program Standard Detail

XD-200529-02