



NOTES:

1. THIS DETAIL SHALL BE USED ONLY WHEN JOB CONDITIONS PREVENT THE USE OF A SLEEVE THAT EXTENDS 2" ABOVE THE SLAB.
2. LINK-SEALS CAN BE USED ONLY FOR RELATIVELY SMALL DIAMETER PIPE PENETRATIONS. VERIFY THAT SLAB THICKNESS ALLOWS PROPER INSTALLATION OF THE LINK-SEAL ASSEMBLY AND THE REQUIRED FIRE STOPPING PRIOR TO APPLYING THIS DETAIL.
3. ALL SEALANTS SHALL BE APPLIED IN STRICT ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. SURFACE OF PIPE, INSULATION AND CONCRETE SHALL BE FREE OF MOISTURE AND DUST PRIOR TO APPLICATION OF SEALANT.

MD ANDERSON CANCER CENTER
Facilities Planning Design & Construction

ISSUE	DATE
①	04-06-2004
①	04-14-2006
②	09-22-2009

FLOOR PENETRATION
Cored/Flush/Non-Insulated

Facility Program Standard Detail

XD-200529-03