



NOTES:

1. ALL SEALANTS SHALL BE APPLIED IN STRICT ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. SURFACE OF PIPE, INSULATION, SLEEVE AND CONCRETE SHALL BE FREE OF MOISTURE AND DUST PRIOR TO APPLICATION OF SEALANT.

MD ANDERSON CANCER CENTER
Facilities Planning Design & Construction

ISSUE	DATE
①	04-06-2004
①	11-21-2005
②	04-14-2006

FLOOR PENETRATION
CAST-IN-PLACE/2" DAM

Facility Program Standard Detail

XD-200529-08