


ALL CONDUIT STUB UPS FOR DATA AND CRITICAL ALARM SHALL HAVE A 90 DEGREE BEND 18" LONG, COMPRESSION CONNECTORS, AND INSULATING BUSHINGS ON ENDS. IN LABS WITH NO CEILINGS, THE CONDUITS SHALL BE ROUTED TO THE CORRIDOR SPACE. USE 3/4" CONDUIT FOR SINGLE OUTLETS AND 1" FOR 3 OR MORE OUTLETS.

MD ANDERSON CANCER CENTER Facilities Planning Design & Construction	ISSUE	DATE	SURFACE STUB-UP (FOR RESEARCH PROJECTS)
		10-15-2009	
Facility Program Standard Detail			EE-260533-04