



ALL CONDUIT STUB UPS FOR DATA AND CRITICAL ALARM SHALL HAVE A 90 DEGREE BEND 18" LONG, COMPRESSION CONNECTORS, AND INSULATING BUSHINGS ON ENDS. IN LABS WITH NO CEILINGS, THE CONDUITS SHALL BE ROUTED TO THE CORRIDOR SPACE. USE 3/4" CONDUIT FOR SINGLE OUTLETS AND 1" FOR 3 OR MORE OUTLETS.

MD ANDERSON CANCER CENTER
Facilities Planning Design & Construction

ISSUE	DATE
△	10-15-2009

RECESSED STUB-UP
(FOR RESEARCH PROJECTS)

Facility Program Standard Detail

EE-260533-05