



NOTE:
 WHERE SURFACE MOUNTED RACEWAY IS TO BE
 INSTALLED ON EXISTING CMU WALL OR
 INTERNALLY INACCESSIBLE WALL, CONTRACTOR
 IS TO USE FACTORY ENTRANCE END FITTING
 FOR CONNECTING SURFACE CONDUIT TO
 RACEWAY.

RACEWAY WALL INSTALLATION ELEVATION

MD ANDERSON CANCER CENTER Facilities Planning Design & Construction	ISSUE	DATE	SURFACE RACEWAY ACCESS
	△	10-15-2009	
Facility Program Standard Detail	△	03-17-2015	EE-260533-07